

ANNO 2018 - Impianto depurazione di BELLINZAGO - Campione medio composito sulle 24 ore Limite di legge Tab. 1 All. 5 DLgs 152/06

		COD		BOD5		SST		P tot		N tot	
		Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita
	u.m.	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
N°	V.L.		125		25		35		2		15
1	10/01/18	250,0	21,0	72,0	< 5	39,0	1,0	2,6	0,2	27,8	10,8
2	16/01/18	518,0	31,0	264,0	< 5	84,0	7,0	7,8	0,4	45,6	10,4
3	05/02/18	638,0	32,0	225,0	9,0	106,0	5,0	6,0	0,4	40,1	15,0
4	07/02/18	148,0	19,0	75,0	5,0	41,0	1,0	2,6	0,3	17,0	6,8
5	14/03/18	492,0	56,0	211,0	17,0	91,0	11,0	5,5	0,5	33,9	11,0
6	30/03/18	471,0	27,0	250,0	5,0	95,0	4,0	5,4	0,2	30,2	13,8
7	11/04/18	173,0	24,0	91,0	< 5	49,0	1,0	3,3	0,2	20,9	12,8
8	26/04/18	761,0	32,0	476,0	< 5	157,5	4,0	8,3	0,3	43,3	13,0
9	03/05/18	369,0	< 12,6	117,0	< 5	120,0	9,0	4,2	0,2	26,6	12,8
10	16/05/18	464,0	21,0	266,0	< 5	80,0	3,0	5,4	0,2	34,6	10,1
11	13/06/18	358,0	23,0	107,0	< 5	82,0	1,0	4,3	0,6	26,8	10,8
12	26/06/18	561,0	27,0	167,0	< 5	141,0	5,0	6,6	0,9	42,7	14,9
13	03/07/18	370,0	36,0	185,0	5,0	139,0	16,0	7,5	0,8	41,5	10,4
14	12/07/18	356,0	54,0	195,0	< 5	102,0	9,0	4,6	0,7	28,9	10,0
15	16/08/18	1043,0	60,0	464,0	6,0	114,0	2,0	7,4	0,6	41,4	14,9
16	28/08/18	1051,0	67,0	276,0	13,5	305,0	20,0	7,3	0,5	49,1	10,6
17	14/09/18	757,0	14,4	300,0	< 5	110,0	10,0	6,7	0,3	36,2	10,6
18	20/09/18	803,0	20,0	400,0	8,0	200,0	10,0	8,3	0,4	43,4	7,1
19	02/10/18	628,0	28,0	209,0	9,0	157,0	9,0	5,5	0,6	27,6	10,9
20	23/10/18	640,0	16,0	390,0	5,0	150,0	< 4	9,1	0,2	43,1	10,7
21	05/11/18	51,0	15,7	153,0	5,0	32,0	4,0	1,9	0,2	15,6	6,6
22	20/11/18	477,0	9,8	216,0	5,0	130,0	4,0	5,8	0,2	40,9	15,0
23	03/12/18	629,0	12,0	440,0	5,0	140,0	4,0	7,3	0,4	45,2	5,6
24	27/12/18	680,0	16,0	460,0	6,0	160,0	4,0	6,2	0,2	56,8	7,7

COD IN COD OUT BOD IN BOD OUT SST IN SST OUT P IN P OUT N IN N OUT

MEDIA ANNUA 529 29 250 7 118 6 6 0,39 36 10,9

Il sistema di riferimento per il controllo dello scarico dell'impianto di trattamento, come indicato in A.U.A., per i parametri di azoto totale e Fosforo totale il limite è rapportato alla concentrazione media annua