

ANNO 2018 - Impianto depurazione di BRIGA NOVARESE - Campione medio composito sulle 24 ore Limite di legge Tab. 1 e 2 All. 5 DLgs 152/06

		COD		BOD5		SST		P tot		N tot	
		Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita
	u.m.	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
N°	V.L.		125		25		35		2,0		15
1	16/01/2018	206,0	15,0	140,0	5,0	34,0	3,0	3,12	0,05	35,7	15,0
2	30/01/2018	170,0	12,0	75,0	4,0	26,0	3,0	2,57	0,08	26,1	7,98
3	22/02/2018	307,0	15,0	210,0	5,0	40,0	3,0	4,21	0,1	39,6	14,9
4	27/02/2018	282,0	18,0	190,0	6,0	80,0	6,0	3,76	0,11	47,7	11,5
5	13/03/2018	153,0	12,0	40,0	4,0	18,0	3,0	3,64	0,08	26,4	5,49
6	27/03/2018	252,0	41,0	160,0	18,0	44,0	3,0	4,11	0,19	35,2	6,28
7	03/04/2018	165,0	13,0	114,0	4,0	30,0	3,0	3,59	0,12	37,3	6,01
8	24/04/2018	357,0	19,0	240,0	5,0	40,0	0,0	2,56	0,07	41,8	7,42
9	08/05/2018	165,0	27,0	100,0	8,0	46,0	3,0	3,30	0,15	36,70	6,64
10	22/05/2018	161,0	17,0	98,0	5,0	26,0	4,0	1,62	0,33	16,80	1,00
12	12/06/2018	183,0	26,0	100,0	10,0	60,0	4,0	3,78	0,08	38,70	4,57
11	26/06/2018	189,0	27,0	110,0	9,0	80,0	4,0	4,79	0,16	57,40	5,97
13	10/07/2018	232,0	35,0	160,0	12,0	60,0	4,0	3,67	0,22	40,00	3,36
14	24/07/2018	150,0	29,0	90,0	8,0	60,0	4,0	8,99	1,72	36,20	4,93
15	21/08/2018	281,0	21,0	178,0	6,0	60,0	4,0	3,89	0,13	33,60	17,50
16	28/08/2018	218,0	20,0	100,0	5,0	60,0	4,0	4,19	0,10	38,10	18,30
17	18/09/2018	244,0	21,0	150,0	8,0	67,0	3,0	3,96	0,07	35,7	13,4
18	25/09/2018	282,0	17,0	135,0	5,0	100,0	4,0	5,14	0,1	57,5	13,6
19	09/10/2018	335,0	23,0	130,0	8,0	140,0	4,0	5,19	0,2	45,0	12,9
20	16/10/2018	279,0	15,0	120,0	5,0	60,0	4,0	4,62	0,108	40,5	13,1
21	13/11/2018	64,0	10,0	32,0	5,0	8,0	4,0	1,58	0,34	16,6	10,2
22	27/11/2018	94,0	16,0	60,0	5,0	20,0	4,0	1,68	0,24	20,1	9,63
23	11/12/2018	222,0	22,0	145,0	8,0	100,0	5	4,38	0,31	38,9	17,2
24	18/12/2018	259,0	15,7	155,0	8,0	130,0	4	5,22	0,2	44,6	23,3

	COD IN	COD OUT	BOD IN	BOD OUT	SST IN	SST OUT	P IN	P OUT	N IN	N OUT
MEDIA ANNUA	218,8	20,3	126,3	6,9	57,9	3,6	3,7	0,2	36,9	10,4

ANNO 2018 - Impianto depurazione di BORGOMANERO - Campione medio composito sulle 24 ore Limite di legge Tab. 1 e 2 All. 5 DLgs 152/06

		COD		BOD5		SST		P tot		N tot	
		Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita	Ingresso	Uscita
	u.m.	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
N°	V.L.		125		25		35		2,0		15
1	16/01/2018	290,0	26,0	198,0	8,0	52,0	3,0	7,9	0,4	62,8	14,3
2	30/01/2018	243,0	15,0	140,0	5,0	60,0	3,0	5,04	0,23	61,6	15,3
3	13/02/2018	259,0	21,0	168,0	8,0	36,0	3,0	3,9	1,35	37,3	23,9
4	06/03/2018	382,0	25,0	270,0	8,0	50,0	2,0	3,87	1,37	38,2	20,7
5	20/03/2018	122,0	27,0	76,0	8,0	18,0	2,0	1,9	0,79	24,0	13,9
6	27/03/2018	373,0	56,0	250,0	22,0	68,0	6,0	3,87	2,0	34,8	7,4
7	03/04/2018	220,0	34,0	150,0	10,0	26,0	22,0	3,53	1,83	41,3	14,9
8	18/04/2018	111,0	20,0	70,0	8,0	28,0	0,0	1,92	0,8	22,0	10,8
9	08/05/2018	338,0	27,0	200,0	10,0	60,0	4,0	2,73	0,58	26,6	10,5
10	22/05/2018	67,0	36,0	40,0	15,0	28,0	14,0	1,69	1,72	18,2	3,8
12	12/06/2018	107,0	25,0	70,0	8,0	28,0	4,0	1,95	0,65	19,2	7,2
11	26/06/2018	100,0	18,0	66,0	5,0	10,0	4,0	2,32	0,81	19,5	8,9
13	17/07/2018	148,0	28,0	98,0	10,0	40,0	4,0	2,03	0,61	25,4	6,3
14	24/07/2018	200,0	21,0	136,0	8,0	68,0	4,0	2,74	0,21	26,6	7,7
15	07/08/2018	273,0	27,0	160,0	8,0	54,0	4,0	2,30	0,51	18,5	6,0
16	21/08/2018	309,0	17,0	218,0	5,0	40,0	4,0	2,66	0,59	20,1	7,2
17	04/09/2018	122,0	16,0	46,0	4,0	40,0	3,0	1,93	0,47	19,2	8,51
18	11/09/2018	136,0	16,0	70,0	5,0	30,0	1,0	2,06	0,95	16,4	6,95
19	16/10/2018	210,0	16,0	105,0	5,0	20,0	3,0	2,99	0,37	28,2	13,4
20	23/10/2018	283,0	15,0	175,0	5,0	110,0	3,0	3,66	0,39	29,3	8,9
21	13/11/2018	94,0	10,0	64,0	5,0	60,0	4,0	1,71	0,18	17,1	8,33
22	27/11/2018	95,0	15,0	50,0	5,0	28,0	8,0	1,87	0,25	22,1	5,9
23	04/12/2018	192,0	16,0	40,0	5,0	230,0	8,0	4,31	0,98	25,8	10,9
24	11/12/2018	238,0	13,0	105,0	5,0	60,0	5,0	3,16	0,67	30,6	11,0

	COD IN	COD OUT	BOD IN	BOD OUT	SST IN	SST OUT	P IN	P OUT	N IN	N OUT
MEDIA ANNUA	204,7	22,5	123,5	7,7	51,8	4,9	3,0	0,8	28,5	10,5